

LIST OF REQUIRED INSPECTIONS For DECKS/PORCHES and SMALL ADDITIONS

SONO TUBES INSPECTION

ALL PIER COMPONENTS SHALL BE INSTALLED AND BACKFILLED

A taped measurement shall be performed from inside the component

ROUGH BUILDING INSPECTION

ALL BUILDING AND OTHER MATERIALS REMOVED FROM THE SITE

If required (Additions and some Farmers Porches)

- a) All rough electric work completed and signed off by the Electrical Inspector.
- b) All rough plumbing work completed and signed off by the Plumbing Inspector.
- c) All chimney work with flashing to code complete.
- d) All rough framing work including interior ceiling strapping, partitions, stairways, exterior stairways, exterior decks and porches.
- e) All penetrations in the top and bottom plates, draft-stopped with ASTM E-136 approved filler.

FINAL INSPECTION

ALL BUILDING AND OTHER MATERIALS REMOVED FROM ALL AREAS AROUND THE HOUSE.

If required (Additions and some Farmers Porches)

- 1- Final wiring signed off by the Electrical Inspector.
- 2- Final plumbing signed off by the Plumbing Inspector.
- 3- Final inspection from a representative of the Assessors office.

ONLY AFTER ALL of the aforementioned Inspectors have been SIGNED, the Inspector of Buildings shall be called for a FINAL INSPECTION

*I UNDERSTAND THAT ANY VIOLATIONS TO THIS SCHEDULE WILL RESULT IN A \$50.00
REINSERTION FEE AND NO FURTHER INSPECTIONS UNTIL IT IS PAID IN FULL*

SIGN NAME: _____ DATE: _____